




## EU Type Examination Certificate CML 17ATEX2046X Issue 0

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Solenoid Assembly Type EP000/ia**
- 3 Manufacturer **Pneumatrol Limited**
- 4 Address **West End Business Park,  
Blackburn Road,  
Oswaldtwistle, Nr Accrington,  
Lancashire, BB5 4WZ  
United Kingdom**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Certification Management Limited, Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK, Notified Body Number 2503, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN 60079-0:2012+A11:2013


EN 60079-11:2012

- 10 The equipment shall be marked with the following:



Ex ia IIC T6...T5 Ga

Tamb: See Description



Ex ia IIIB T135°C T<sub>500</sub> 175°C Da

Tamb: -40 °C to +65 °C



**CML 17ATEX2046X  
Issue 0**

## 11 Description

The Solenoid Assembly Type EP000/ia is designed as an electro-magnetic actuator for a control valve. the coil is mounted on a glass filled nylon former and two shunt connected diodes or a bridge rectifier are fitted to a printed circuit board beneath the terminal block.

The unit is contained in an enclosure of steel, stainless steel or aluminium and the coil and diodes are encapsulated to a depth of 1mm. External connection may be to a terminal block contained within the enclosure, to a plug and socket, or via a flying lead.

### Nomenclature:

#### Solenoid Assembly Type EP000/ia/xx

Where xx represents the connection type:

- FL - 2 x 22 AWG 230 mm Flying Leads
- TB - 2-Pole Terminal Block 90° Conduit Entry
- IL - 2-Pole Terminal Block, In-Line Conduit Entry
- PS - 2 Pin Plug (with accompanying 2 -pin socket) with gasket
- SS - Stainless Steel Case

### Ratings:

#### Group II:

U<sub>i</sub> = 31 V  
I<sub>i</sub> = 0.67 A

Pi =	T-Class	Pi = 1 W	Pi = 2.98 W
	T5	Tamb: -40 °C to +65 °C	Tamb: -40 °C to +65 °C
	T6	Tamb: -40 °C to +65 °C	Tamb: -40 °C to +50 °C

C<sub>i</sub> = 0  
L<sub>i</sub> = 0

#### Group III:

U<sub>i</sub> = 31 V  
I<sub>i</sub> = 0.67 A  
P<sub>i</sub> = 2.98 W  
C<sub>i</sub> = 0  
L<sub>i</sub> = 0



CML 17ATEX2046X  
Issue 0

## 12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	14/07/2017	R2012A	Initial Issue

Note: Drawings that describe the equipment or component are listed in the Annex.

## 13 Conditions of manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- 13.1 Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- 13.2 The equipment shall be subjected to routine tests in accordance with the requirement of EN 60079-11, Clause 6.3.13 Dielectric strength. The insulation between the intrinsically safe circuit and the frame of the electrical equipment or parts which may be earthed shall be capable of complying with the test described in 10.3 at an r.m.s. a.c. test voltage of 500 V r.m.s. for at least 60 s. No breakdown shall occur.

## 14 Special Conditions for Safe Use (Conditions of Certification)

The following conditions relate to safe installation and/or use of the equipment.

- 14.1 The enclosure is manufactured from Aluminium. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered during installation, particularly if the equipment is installed in a Zone 0 or 20 location.
- 14.2 Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on these surfaces, such as Steam generation or blown/fast moving dust. This is particularly important if the equipment is installed in a Zone 0 or 20 location. In addition, the equipment shall only be cleaned with a damp cloth.
- 14.3 Full Temperature Class/Ambient Temperature Range information is not present on the equipment marking label, refer to the Description for full equipment marking details.

## Certificate Annex



**Certificate Number** CML 17ATEX2046X  
**Equipment** Solenoid Assembly Type EP000/ia/xx  
**Manufacturer** Pneumatrol Limited

The following documents describe the equipment or component defined in this certificate:

### Issue 0

Drawing No	Sheets	Rev	Approved date	Title
CV5004	1 of 1	8	14/07/2017	EP000/IA & Variant Coil Assembly
V6207G2S	1 of 1	2	14/07/2017	ATEX/IECEx Label for EP000/ia