



中国国家强制性产品认证证书



证书编号：2020322307001726

认证委托人名称：Pneumatrol Limited
 认证委托人地址：West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK
 生产者名称：Pneumatrol Limited
 生产者地址：West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK
 生产企业名称：Pneumatrol Limited
 生产企业地址：West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK

产品名称：电磁线圈
 系列、规格、型号：EP000/ia 系列
 标准：GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、GB 12476.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月22日 有效期至：2025年9月21日

首次发证日期：2020年9月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307001726

APPLICANT: Pneumatrol Limited
ADDRESS: West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK
MANUFACTURER: Pneumatrol Limited
ADDRESS: West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK
FACTORY: Pneumatrol Limited
ADDRESS: West End Business Park, Blackburn Road, Oswaldtwistle, Lancashire, UK

PRODUCTNAME: Solenoid Assembly
SERIES,SPECIFICATION,MODEL: EP000/ia series
STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
 GB 12476.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 22, 2020 **Valid until:** September 21, 2025

Date of original certification:September 22, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL: 
 Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001052



中国国家强制性产品认证证书



证书编号: 2020322307001726

附 件

产品名称: 电磁线圈

型号规格: EP000/ia/FL, EP000/ia/TB, EP000/ia/IL, EP000/ia/PS, EP000/ia/SS

防爆标志: Ex ia IIC T5/T6 Ga; Ex iaD 20 T135°C

电气参数: 本安参数: $U_i: 31V$, $I_i: 0.67A$, $C_i: 0$, $L_i: 0$; P_i 见下表:

允许使用环境温度范围	温度组别	最大输入功率 P_i (W)
-40°C ~ +65°C	T6	1
-40°C ~ +65°C	T5	2.98
-40°C ~ +50°C	T6	2.98
-40°C ~ +65°C	T135°C	2.98

批 准:



上海仪器仪表自控系统检验测试所有限公司